



Government of West Bengal  
Office of the Divisional Fire Officer  
West Bengal Fire & Emergency Services  
Sepoy Bazar, P.O.:- Medinipur, P.S.:- Kotwali, Pin:- 721101

Memo No.:FSR/0125186231500314

Date : 10-07-2024

From :  
Divisional Fire Officer  
Paschim Medinipur Division,  
West Bengal Fire & Emergency Services

To :  
VIDYASAGAR TEACHER'S TRAINING INSTITUTE (B.ED & D.EL.ED) COLLEGE  
MOUZA - AKALPOUSH, J.L NO - 09, PLOT NO - 894, P.O - AKALPOUSH, P.S - DEBRA, DIST - PASCHIM MEDINIPUR,  
PIN - 721156

Sub : Fire Safety Certificate for an Existing construction G+1 storied and 2nd Floor proposed Building under group of Educational Building as per NBC Part IV, in the name of "VIDYASAGAR TEACHER'S TRAINING INSTITUTE (B.ED & D.EL.ED) COLLEGE" Mouza - Akalpoush, J.L. No - 09, Plot No - 894, P.O - Akalpoush, P.S - Debra, Dist - Paschim Medinipur, Pin - 721156.

This is in reference to your AIN 211892406300000472 dated 14-May-2024 regarding Fire Safety Certificate for an Existing construction G+1 storied and 2nd Floor proposed Building under group of Educational Building as per NBC Part IV, in the name of "VIDYASAGAR TEACHER'S TRAINING INSTITUTE (B.ED & D.EL.ED) COLLEGE" Mouza - Akalpoush, J.L. No - 09, Plot No - 894, P.O - Akalpoush, P.S - Debra, Dist - Paschim Medinipur, Pin - 721156.

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

**Recommendation:**

On conditional Fire Safety certificate issued, subject to comply the under mentioned condition with in Six months from the issuing of this certificate and intimate to this end positively for regularization of this Certificate.

Condition :-

A) Provide the Under Ground water reservoir having capacity not less than 300000 ltrs.



The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892406300000472



Government of West Bengal  
Office of the Divisional Fire Officer  
West Bengal Fire & Emergency Services  
Sepoy Bazar, P.O.:- Medinipur, P.S.:- Kotwali, Pin:- 721101

Memo No.:FSR/0125186231500314

Date : 10-07-2024

From :  
Divisional Fire Officer  
Paschim Medinipur Division,  
West Bengal Fire & Emergency Services

To :  
VIDYASAGAR TEACHER'S TRAINING INSTITUTE (B.ED & D.EL.ED) COLLEGE  
MOUZA - AKALPOUSH, J.L NO - 09, PLOT NO - 894, P.O - AKALPOUSH, P.S - DEBRA, DIST - PASCHIM MEDINIPUR,  
PIN - 721156

Sub : Fire Safety Certificate for an Existing construction G+1 storied and 2nd Floor proposed Building under group of Educational Building as per NBC Part IV, in the name of "VIDYASAGAR TEACHER'S TRAINING INSTITUTE (B.ED & D.EL.ED) COLLEGE" Mouza - Akalpoush, J.L. No - 09, Plot No - 894, P.O - Akalpoush, P.S - Debra, Dist - Paschim Medinipur, Pin - 721156.

This is in reference to your AIN 211892406300000472 dated 14-May-2024 regarding Fire Safety Certificate for an Existing construction G+1 storied and 2nd Floor proposed Building under group of Educational Building as per NBC Part IV, in the name of "VIDYASAGAR TEACHER'S TRAINING INSTITUTE (B.ED & D.EL.ED) COLLEGE" Mouza - Akalpoush, J.L. No - 09, Plot No - 894, P.O - Akalpoush, P.S - Debra, Dist - Paschim Medinipur, Pin - 721156.

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

**Recommendation:**

On conditional Fire Safety certificate issued, subject to comply the under mentioned condition with in Six months from the issuing of this certificate and Intimate to this end positively for regularization of this Certificate.

Condition :-

A) Provide the Under Ground water reservoir having capacity not less than 300000 ltrs.



B) All pump will be having auto Driven Facilities.

Other General recommendation are as below -

1. Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No perking will be allowed on the driveway.
  2. Directional sign and escape route shall be displayed prominently.
  3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
  4. The interior finish decoration of building shall be made with low flame spread material confirming I.S. Specification.
  5. The notice of Fire Fighting and Evacuation with "Exit Sign" from the building shall be prepared and displayed at all vulnerable places of the building.
  6. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing
  7. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
  8. First - Aid Fire Fighting system shall be provided as per I.S Specification.
  9. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
  10. If required the old line shall have to be replace with new line the cables shall always be laid in M.S. conduit pipes continuously bounded to the earth.
  11. Periodical flashing of water from the Hydrants pipe line shall be made to maintain the efficient working performance of above mentioned system.
  12. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
  13. Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling and ducts.
  14. A Fire control room with close circuit T.V. system will have to be installed which will observe all the floor of the building.
  15. Transformer and Switch Gear room shall be protected with automatic CO2 or D.C.P. Fire extinguisher conforming I.S. Specification.
  16. A trained Firemen shall be maintained round the clock for safety of the building.
  17. This Fire Safety Certificate is valid for three year and has to be renewed every three year from the date of issue of this letter.
  18. Each three year a certificate is to be obtained from the Divisional Fire Officer, Paschim Medinipur Division, West Bengal Fire & Emergency Services, performance of all the Life & Fire Safety arrangements and installation of the building.
- N.B: No addition and alteration without prior permission of West Bengal Fire & Emergency Services. Otherwise the Fire Safety certificate will be treated as cancelled.



The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892406300000472

Valid Upto : 09-Jul-2027

Memo No. FSR/0125185231500314



Signature valid

Digitally Signed.  
Name: Banu Kurni Chowdhury  
Date: 10-Jul-2024 12:59:31  
Reason: D-Sign  
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 21189240630000472